



UL Product iQ
UL'S NEXT GENERATION CERTIFICATIONS SEARCH
The same trusted data in a modern search engine.

NOW
AVAILABLE

▶ LEARN MORE

HCBZ.EX15669
Indicator Posts, Gate Valve

[Page Bottom](#)

Indicator Posts, Gate Valve

[See General Information for Indicator Posts, Gate Valve](#)

TIANJIN GALAXY VALVE CO LTD

EX15669

15 Tianhua Rd
Balitai Industrial Area
Jinnan District
300350 Tianjin, CHINA

Underground types, adjustable length, for use with gate valve sizes 14 through 24 in., Model(s) FIG. NO. G322

Underground types, adjustable length, for valve sizes 4-12 in., Model(s) Fig. No. G388

Wall types, for valve sizes 4-12 in., Model(s) Fig. No. W388

[Last Updated](#) on 2016-10-28

[Questions?](#)

[Print this page](#)

[Terms of Use](#)

[Page Top](#)

© 2018 UL LLC

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2018 UL LLC".

CERTIFICATE OF COMPLIANCE

Certificate Number 20161028-EX15669
Report Reference EX15669-20101103
Issue Date 2016-OCTOBER-28

Issued to: TIANJIN GALAXY VALVE CO LTD
15 TIANHUA RD
BALITAI INDUSTRIAL AREA
JINNAN DISTRICT
TIANJIN
300350 CHINA

This is to certify that representative samples of INDICATOR POSTS, GATE VALVE
See addendum for models.

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 789, Indicator Posts for Fire-Protection Service
ULC/ORD C789-75, Other Recognized Document Guide for the Investigation of Indicator Posts for Fire Protection Service

Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20161028-EX15669
Report Reference EX15669-20101103
Issue Date 2016-OCTOBER-28

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Fig. No. G388 vertical, adjustable type, indicator post for use with gate valve sizes 4 through 12 in.

FIG. NO. G322 vertical, adjustable type, indicator post for use with gate valve sizes 14 through 24 in.

These devices are equipped with the following operating handles.

Model	Style	Handwheel Diameter / Wrench Length
FIG. NO. G322	Wrench	457 mm



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

